



The Right Connection™

EU DECLARATION OF CONFORMITY
Rev G

Dixon Bayco Division of the Dixon Valve and Coupling Company declares under our sole responsibility that the products listed below conform with the relevant provisions of ATEX directive 2014/34/EU.

Products: FT101 5-wire Overfill Sensor Probe
FT151 2-wire Overfill Sensor Probe
FT202 2-Wire Overfill Sensor Probe
FT152 2-wire Retain Sensor Probe
FT206 2-wire Retain Sensor Probe

Notifying Body: CSA Group Netherlands B.V
Notifying Body No. 2813
Utrechtseweg 310,
6812 AR, Arnhem,
Netherlands

Conformity has been demonstrated with reference to the following documentation:

EU type-examination certificates: Sira 09ATEX2039X – issue 8
Sira 09ATEX2040X – issue 8
Sira 09ATEX2041X – issue 6
Sira 09ATEX2042X – issue 5
Sira 09ATEX2043X – issue 6

Quality Assurance Notification(QAN): Sira 09 ATEX M443 issued Jan 28, 2020

Compliance with the Essential Health & Safety Requirements has been assessed by reference to the following standards: EN 60079-0:2018
EN 60079-11:2012

Current Harmonized Standards: IEC60079-0:2017
IEC60079-11:2011

The harmonized standards have been compared to the standards used for certification purposes and no changes in the “state of the art” apply to the equipment.

Date of certification July 20, 2009
Manufacturer: Dixon Bayco

Robert C Koeninger
V.P. and General Manager, Dixon
February 26, 2020

Dixon Bayco

7280 Union Centre Blvd.
West Chester, OH 45014
www.dixonbayco.com

ph 513-874-8499
fax 513-874-8399